



# ULiQ for Surge Protective Devices



Surge Protective Devices

E326289

Guide Information

## Citel America Inc

10108 USA Today Way, Miramar FL 33025

### Model(s): M50F-277Y-A\*, M50F-277Y-B\*

Permanently Connected

<u>SPD Type</u>	<u>Volts (V)</u>	<u>AC/DC DC PV</u>	<u>Phase</u>	<u>Amps (A)</u>	<u>Ambient Min(°C)</u>	<u>Ambient Max(°C)</u>	<u>Mode</u>	<u>VPR (Vpk)</u>	<u>MCOV (V)</u>	<u>In (kA)</u>	<u>SCCR (kA)</u>
2	480/277	AC	3Y	n/a	-35	80	L-L	2500	560	20	150
							L-N	1200	320		
							L-G	1200	320		
							N-G	1200	280		

Evaluated to: UL 1449 4th Ed. Rev: 2016-03-17 and CSA Electrical Certification Notice 516/CSA C22.2 No. 8 13

\* - Complementary Listed as EMI Filters.

SPDs investigated for Type 1 applications are automatically suitable for Type 2 applications and may be marked for SPD Type 1 and/or Type 2 applications. SPDs only marked "SPD Type 2" are not suitable for Type 1 applications.

Where a minimum ambient temperature is not specified, assume 0°C unless the product is marked otherwise or with an Outdoor use Environmental Rating. See Electrical Equipment for Use in Ordinary Locations (AALZ) for details regarding Environmental Ratings.

Report

Date: 2015-07-23

Last 2015-10-16

Revised:

© 2018 UL LLC

